

**Pittsburgh Water and Sewer Authority
Notification**

Ward 04

Service Order No: SORD00000283211

Date/Time Printed: 04/10/2019 13:26

Description: CMMS

Complaint Code 725 Contractor Restoration

Entered By MMadero Date Entered 3/6/2015

Appt Date 3/6/2015

House Number
Street Location RUSKIN ST And 5TH AVE

Reported By 911 412-255-2935

Foreman Code WD-5 McCarthy

Given To 15034 JOHN MCCARTHY

Investigation results

Repair Code

Department CMMS-BRILLIANT

Group Code 2 Water

Work Completion Date _____ Completed By _____

Repair

Raven Edmond 02/05/2016 Completed by Contractor 06/01/15
John Koller 03/09/2015 SIDEWALK REPAIR, 3 PADS, EACH 5 X 5. 3/7/15 WD 14 CUMMINGS
John Koller 03/09/2015 INSTALLED 4 FEET OF 6 INCH PIPE TO REPAIR SPLIT ON 6 INCH MAIN. WD 14
CUMMINGS, 34 CIMINO. 3/7/15
Mark Madero 03/06/2015 POSSIBLE MAIN BREAK

// MAM 03-06-15 0727

Pittsburgh Water and Sewer Authority
Notification

Ward 04

Service Order No: SORD00000490488

Date/Time Printed: 04/10/2019 13:31

Description: CMMS

Complaint Code 510 Investigate Main Break

Entered By MMadero Date Entered 12/12/2015

Appt Date 12/12/2015

House Number
Street Location LOTHROP ST And 5TH AVE & VICTORIA ST

Reported By WD4

Foreman Code WD-4 Koller

Given To 11610 JOHN KOLLER

Investigation results

Repair Code

Department CMMS-BRILLIANT

Group Code 2 Water

Work Completion Date _____ Completed By _____

Repair

Mark Madero 12/12/2015 REPAIR LEAK ON WATER MAIN , 1 CALL SN 20153460105 PLACED FOR TOMORROW
12-13-15

// MAM 12-12-15 1144